



## PLUTO LNG TRAIN 2

MR Number: 26221-100-MRA-ETPO-00001

Title: Power Transformers

Scope of Work: Power transformers shall be liquid immersed (Midel 7131 or natural ester FR3 fluid).

Scope includes: supply of 11kV/34.5kV GTG step-up transformer (50MVA), 33kV/ 7.2kV transformers (17.5MVA), 6.6kV/720V transformers (2.5MVA) and 6.6kV/ 420V transformers (2MVA)

Compliance with applicable Australian/local regulations, statutory requirements, Australian codes and standards is required.