

EXPRESSION OF INTEREST (EOI)

Project	CERES
Company / Client	Perdaman Chemicals and Fertilisers Pty Ltd
Package Material Requisition Number	0000-GA-E-60933
Package Title	FIRE WATER CAST VALVES
1. SUBMISSION PROCEDURE	
EOI Instructions	<p>Supplier(s) are invited to express interest by registering on ICN Gateway where competency and previous positive experiences of similar supply of goods / services can be demonstrated.</p> <p>When submitting interest registrants will be asked to complete an expression of interest document. The registrant's response will form their Expression of Interest (EOI) for material and/or services.</p> <p>Suppliers will only be considered for Prequalification should they satisfy stated criteria, including but not limited to Health, Safety & Environmental Management, Quality management, financial standing, relevant experience and availability.</p>
EOI Closing Date	Please submit by close of business on 12/04/2024
Returnable Schedules	Where the EOI calls for any Returnable Schedules, please ensure all schedules are submitted.
Contact	<p>All initial enquiries should be made through the Industry Capability Network Western Australia (ICNWA).</p> <p>Andie Pfaff Andie.Pfaff@icnwa.org.au +61 (08) 9365 7442</p>
URL	<p>For more information regarding the Perdaman, refer</p> <ul style="list-style-type: none"> https://www.perdamanindustries.com.au/scjv/
2. INDICATIVE SCOPE OF WORK	
Package Description	<p>Overview</p> <p>Saipem Australia Pty Ltd and Clough Projects Australia Pty Ltd Joint Venture (herein referred to as the "CONTRACTOR") has reached an agreement with Perdaman Chemicals and Fertilisers Pty Ltd (herein referred to as the "OWNER") for the Engineering, Procurement, Construction and Commissioning of the PROJECT CERES located in Burrup Strategic Industrial Area, Burrup Peninsula, Western Australia.</p> <p>Perdaman Chemicals and Fertilisers Pty Ltd (OWNER) is focused on the development of Perdaman - Project CERES which shall be the world's largest gas stream ammonia-urea plant with a production capacity of 2.14 MMTPA granular urea.</p> <p>General Scope of Supply / Services</p> <p>Design, Materials, Fabrication, Testing, Inspection, Painting, Packing, Marking and Supply of FIRE WATER CAST VALVES listed in ANNEXURE-1.</p> <p>The following must be provided:</p> <ul style="list-style-type: none"> Technical deviations list

	<ul style="list-style-type: none"> • Special tools list • Schedule of rates • Erection, Pre-commissioning, Commissioning and Start-up Spares (Base scope) • Capital spares if any to be considered in base scope with separate price list • Two Years operational Spares price list • Quality assurance • Site Supervision (Per Diem rates for site supervision during erection, pre-commissioning, commissioning, Start-up and site performance testing)
Standards	Compliance with National, International and Industry Standards, Australian and WA Regulatory requirements.
Key Dates	RFQ expected to be issued during 2 nd Week of April 2024
Point of Delivery	Perdaman Fabrication Yard and Site
3. RETURNABLE DOCUMENTS	
List of Returnable Schedules	List of experience on similar equipment supply projects
4. DISCLAIMER	
This Expression of Interest to gain an insight into the capabilities of potential suppliers and/or service providers and not a Tender Invitation or offer - the schedule and content of this work is subject to change pending project demand and timelines.	

ANNEXURE - 1

S.No	Mark / Tag No	Description	Quantity	UOM
1	VSW56	DN:500-Gate Valve - Flanged - CL150 - AS2638.2 - AG FW APPLICATION - Coated SG Iron body with EPDM encapsulated wedge-GA-E-61288-FLGD/FLGD- CL150- RF-ASTM A536 GR.65-45-12-GA-E-60933 -trim:SPECIAL Trim	4	pcs
2	VSW45	DN:400-Gate Valve - Flanged - CL150 - AS2638.2 - UG FW APPLICATION - Coated SG Iron body with EPDM encapsulated wedge-GA-E-61287-FLGD/FLGD- CL150- FF-ASTM A536 GR.65-45-12-GA-E-60933 -trim:SPECIAL Trim	64	pcs
3	VSW60	DN:300-Gate Valve - Flanged - CL150 - AS2638.2 - AG FW APPLICATION - Coated SG Iron body with EPDM encapsulated wedge-GA-E-61288-FLGD/FLGD- CL150- RF-ASTM A536 GR.65-45-12-GA-E-60933 -trim:SPECIAL Trim	1	pcs
4	VSW51	DN:100-Gate Valve - Flanged - CL150 - AS2638.2 - UG FW APPLICATION - Coated SG Iron body with EPDM encapsulated wedge-GA-E-61287-FLGD/FLGD- CL150- FF-ASTM A536 GR.65-45-12-GA-E-60933 -trim:SPECIAL Trim	12	pcs
5	VSW58	DN:400-Gate Valve - Flanged - CL150 - AS2638.2 - AG FW APPLICATION - Coated SG Iron body with EPDM encapsulated wedge-GA-E-61288-FLGD/FLGD- CL150- RF-ASTM A536 GR.65-45-12-GA-E-60933 -trim:SPECIAL Trim	6	pcs
6	VSW49	DN:200-Gate Valve - Flanged - CL150 - AS2638.2 - UG FW APPLICATION - Coated SG Iron body with EPDM encapsulated wedge-GA-E-61287-FLGD/FLGD- CL150- FF-ASTM A536 GR.65-45-12-GA-E-60933 -trim:SPECIAL Trim	6	pcs
7	VSW50	DN:150-Gate Valve - Flanged - CL150 - AS2638.2 - UG FW APPLICATION - Coated SG Iron body with EPDM encapsulated wedge-GA-E-61287-FLGD/FLGD- CL150- FF-ASTM A536 GR.65-45-12-GA-E-60933 -trim:SPECIAL Trim	15	pcs
8	VSW62	DN:200-Gate Valve - Flanged - CL150 - AS2638.2 - AG FW APPLICATION - Coated SG Iron body with EPDM encapsulated wedge-GA-E-61288-FLGD/FLGD- CL150- RF-ASTM A536 GR.65-45-12-GA-E-60933 -trim:SPECIAL Trim	1	pcs
9	VSW63	DN:150-Gate Valve - Flanged - CL150 - AS2638.2 - AG FW APPLICATION - Coated SG Iron body with EPDM encapsulated wedge-GA-E-61288-FLGD/FLGD- CL150- RF-ASTM A536 GR.65-45-12-GA-E-60933 -trim:SPECIAL Trim	11	pcs
10	VSW64	DN:100-Gate Valve - Flanged - CL150 - AS2638.2 - AG FW APPLICATION - Coated SG Iron body with EPDM encapsulated wedge-GA-E-61288-FLGD/FLGD- CL150- RF-ASTM A536 GR.65-45-12-GA-E-60933 -trim:SPECIAL Trim	13	pcs
11	VCAG5	DN:100-Check Valve Swing Type - Aboveground Firewater - AS4794-GA-E-61600-FLGD/FLGD- CL150- RF125 µin.Ra-ASTM A351 CF8M-GA-E-60933 -trim:316	2	pcs
12	VCAF9	DN:400-Check Valve Swing Type - Aboveground Firewater - AS4794-GA-E-61600-FLGD/FLGD- CL150- RF125 µin.Ra-ASTM A351 CF8M-GA-E-60933 -trim:316	2	pcs
		Total	137	pcs

Note: UL/FM and Australian standard certification is mandatory.